

ING

operate and maintain  
accordance with  
manufacturer's instructions  
avoid exposure to fuel  
gases or substances  
which can cause death or  
serious illness. The State of  
California has determined  
that these substances may  
cause cancer, birth defects,  
or other reproductive harm.

035-06374-000C

LISTED 13ML A/C SYSTEMS-EQUIPMENT

MODEL NO.  
D7CG060N09906ECA

SERIAL (S)NKJM121674



FACTORY CHARGED R22 FOR OUTDOOR INSTALLATION ONLY  
TOTAL 6 LB 8 OZS UNIT SUPPLY 208/230V 1PH 60HZ  
CONTROL CIRCUIT 75 VA MIN. CKT. AMPACITY 44.0  
MAXIMUM FUSE SIZE (TIME DELAY) 70 AMPS  
MAXIMUM CIRCUIT BREAKER SIZE 70 AMPS\*

\* USE ONLY HACR TYPE CIRCUIT BREAKER PER UL LISTING.  
FACT. TEST PRESS. HIGH SIDE 450 PSIG LOW SIDE 190 PSIG

QTY	LOADS	HP	VOLTS	PH	HZ	
1	COMPR.		208/230-1-60			28.9 RLA 165.0 LRA
1	I.D. BLO	1.0	208/230-1-60			6.6 FLA
1	O.D. FAN	.25	208/230-1-60			1.3 FLA
1	PWR. VENT	.05	208/230-1-60			.4 FLA

TYPE GAS- NATURAL MANIFOLD PRESS - 3.5" W.C.  
ORIFICE: (42) DRILL SIZE PILOT ORIFICE: (56) DRILL SIZE  
THIS APPLIANCE EQUIPPED ONLY FOR ALTITUDES 0-2000 FT

FOR PURPOSES OF INPUT ADJUSTMENTS:  
NATURAL GAS SUPPLY @ UNIT " W.C.: 10.5 MAX 4.5 MIN  
TOTAL INPUT BTU/HR  
125,000

DESIGNED MAXIMUM OUTLET AIR TEMPERATURE 185 DEG. F.  
FOR 35-65 DEG F RISE AT 0.80" W.C. MAX. EXT. S.P.  
LIMIT CONTROL SETTING 165 DEG. F.  
SEE INSTALLATION INSTRUCTIONS FOR ADDITIONAL  
OPERATING AND INSTALLATION DETAILS.  
GAS FIRED CENTRAL FURNACE WITH COOLING UNIT  
ANSI Z39-19-1997 ACCA-2.3(B)-M97



SAFETY SWITCH

60 AMP. 240 V.A.C.  
PHASE STD. H.P.  
1 10  
3 15

SQUARE D COMPANY  
A-40274-384-01

⚡ DANGER  
HAZARD OF ELECTRICAL SHOCK OR BURN. SEE INSTRUCTIONS INSIDE DOOR.



**CAUTION**  
HANDLING INSTRUCTIONS  
AVERTIR  
INSTRUCTIONS DE MANUTENTION



Model No. 200A  
Serial No. 123456789  
Capacity: 10.0 tons  
Voltage: 208-230V  
Phase: 3  
Frequency: 60 Hz  
Compressor: York  
Condenser Coils: York  
Evaporator Coils: York  
Refrigerant: R-410A  
Net Weight: 150 lbs  
Gross Weight: 180 lbs  
Dimensions: 48" x 36" x 36"  
Installation Instructions: See manual  
Warranty: 5 years parts, 1 year labor

**WARNING** **AVERTISSEMENT**  
Electric Shock Hazard  
Can cause severe personal injury or death.  
Read the Owner's Manual before attempting to install, service, or repair the unit.  
Do not touch the electrical parts of the unit.  
Do not touch the condenser coils and electrical controls.

**Notice to Installer** **AVIS à l'installateur**  
For access to unit. Pour plus d'infos voir le manuel.

**AVERTIR**  
INSTRUCTIONS DE MANUTENTION  
Lecteur de l'avis de sécurité. Lire attentivement les instructions de manutention avant de commencer tout travail de réparation ou d'entretien. Ne pas toucher les parties électriques de l'appareil. Ne pas toucher les bobines du condenseur et les commandes électriques.

For more information, visit us online at [www.york.com](http://www.york.com).  
York is a leader in the HVAC industry for over 100 years.  
We are committed to providing the highest quality products and services to our customers.  
Contact us today for more information.





3600 SPENARD RD

YORK

**CAUTION**  
HANDLING INSTRUCTIONS  
AVERTIR  
INSTRUCTIONS DE MANUTENTION

2

LISTED 13ML A/C SYSTEMS EQ

MODEL NO  
**D7CG060N09906ECA**

SERIAL (S)NLJM132750



FACTORY CHARGED R22 FOR OUTDOOR INSTALLATION ONLY  
TOTAL 6 LB 8 OZS UNIT SUPPLY 208/230V 1PH 60HZ  
CONTROL CIRCUIT 75 VA MIN. CKT. AMPACITY 44.0  
MAXIMUM FUSE SIZE (TIME DELAY) 70 AMPS  
MAXIMUM CIRCUIT BREAKER SIZE 70 AMPS\*

\* USE ONLY HACR TYPE CIRCUIT BREAKER PER UL LISTING.  
FACT. TEST PRESS. HIGH SIDE 450 PSIG LOW SIDE 190 PSIG

QTY	LOADS	HP	VOLTS	PH	HZ	
1	COMPR.		208/230-1-60			28.9 RLA 165.0 LRA
1	I.D. BLO	1.0	208/230-1-60			6.6 FLA
1	O.D. FAN	.25	208/230-1-60			1.3 FLA
1	PWR. VENT	.05	208/230-1-60			.4 FLA

TYPE GAS- NATURAL MANIFOLD PRESS - 3.5" W.C.  
ORIFICE: (42) DRILL SIZE PILOT ORIFICE: (56) DRILL SIZE

THIS APPLIANCE EQUIPPED ONLY FOR ALTITUDES 0-2000 FT  
FOR PURPOSES OF INPUT ADJUSTMENTS:

NATURAL GAS SUPPLY @ UNIT " W.C.: 10.5 MAX 4.5 MIN  
TOTAL INPUT BTU/HR  
125,000

DESIGNED MAXIMUM OUTLET AIR TEMPERATURE 165 DEG. F.  
FOR 35-65 DEG F RISE AT 0.80" W.C. MAX. EXT. S.P.  
LIMIT CONTROL SETTING 165 DEG. F.

SEE INSTALLATION INSTRUCTIONS FOR ADDITIONAL  
OPERATING AND INSTALLATION DETAILS.

GAS FIRED CENTRAL FURNACE WITH COOLING UNIT  
ANSI Z21.47(B)-1997 \* CAN/CGA-2.3(B)-M97  
SUNLINE 2000





LA QUINTA



LAQUINTA

