



TO: ALL PLANHOLDERS OF RECORD
RE: ITB 26T-DV-115 Kenaitze Pointe Mechanical Systems Upgrade
FROM: Rashaad Esters, Procurement Manager
PAGE(S): 25, including this cover sheet
DATE: June 18, 2026

Transmitted herewith is an Addendum to the solicitation listed above. If the Addendum is **not** received in full, please contact the Procurement Office at (907) 793-3000. If all pages of the Addendum are received, please sign this sheet and email it back to CIHA's Procurement Department at Procurement@cookinlethousing.org.

Company's Name

Company's Representative

Date

ITB 26T-DV-115 Kenaitze Pointe Mechanical Systems Upgrade

This document forms a part of and modifies the solicitation as noted below. Respondents must acknowledge receipt of this addendum. Failure to acknowledge receipt of this addendum may subject Respondent to disqualification.

PROJECT: Kenaitze Mechanical Systems Upgrade

FOR: Cook Inlet Housing Authority

The following corrections, clarifications, additions, and/or deletions to the ITB 26T-DV-115 are hereby made a part of said documents. All other terms and conditions remain the same.

This Addendum Shall:

1. Extend the bid deadline to June 30th, 2:00PM
2. Answer questions submitted to Procurement by the submittal due date June 10, 5:00PM
3. Submit electrical drawings requested in the question submittal

**KENAITZE POINTE MECHANICAL SYSTEMS UPGRADE
QUESTIONS AND ANSWERS**

#	Question	Answer
1	Some manufactured equipment are long lead items. This would push the contract beyond the Oct. 30, 2026, completion date. Can the period of performance be extended to Oct. 2027?	Yes. The project completion date has been extended to August 2027
2	Drawing S1.02 and S1.03 shows support platforms with unknown insulation value. Please confirm that cavities are not insulated.	Unable to confirm. For bidding purposes, contractors are to assume these cavities are insulated.
3	Are there electrical drawings available in regard to the RTU replacement?	Yes. See attached.
4	What is the Electrical scope of Add Alt 1? Is the contractor to assume it will be a disconnect-reconnect utilizing existing conduit, conductors and breakers?	Maintain existing circuitry & wiring, replace source circuit breakers.
5	Considering bids are being opened June 24, by the time that submittals are approved and long lead mechanical equipment has arrived the start of construction would likely be into the start of heating months in the fall. Would CIHA consider pushing the completion date of this project so that it could be constructed in spring of 2027 to avoid construction during the fall/winter months?	See response to Question #1
6	Time frame for the project? I do not believe that the equipment will be available with such short notice	See response to Question #1
7	RTU-2 will need access for pipe connections under the unit. Is there sufficient space for that or will roof curb need to be opened up?	Detail 11/M6.01 is showing the valve location to be below the roof. Ceiling of space below may need to be opened. Patched and repaired as required.
8	How many gallons of glycol should be expected to be replaced?	Contractor is responsible for calculating glycol replacement volume based on contractor's shop drawings and/or actual pipe installation, means and method of

**KENAITZE POINTE MECHANICAL SYSTEMS UPGRADE
QUESTIONS AND ANSWERS**

		the demo and replacement of heating elements, etc.
9	Can the Lochinvar boiler exhausts be cascaded into 1 larger vent pipe through the roof?	No. Each boiler shall be exhausted separately.
10	Will the tenant rooms that have the vent shaft be occupied during the project? If so, what accommodation will be made for the contractor for demo and installation? Timeframe?	The tenant rooms will likely be occupied. The contractor is required to provide at least one week's notice prior entry, and the contractor will have access to what is needed to complete the scope of work.
11	Would it be allowed to core drill through the concrete wall for temp heat/water and repair when completed	Yes. Repair must match existing conditions.

ELECTRICAL SYMBOLS

LIGHTING FIXTURE SCHEDULE

TYPE ID	MANUFACTURER MODEL NUMBER	FIXTURE DESCRIPTION	LED		MOUNTING TYPE
			LUMENS	WATTS	
A	JUNO LIGHTING #JSF-7IN-18LM-SWW5-90CRI-MVOLT-ZT-WH	7" ROUND SLIM SURFACE MOUNT WITH SWITCHABLE COLOR TEMPERATURE & WHITE HOUSING.	1,182	12	SURFACE CEILING
A1	JUNO LIGHTING #JSF-13IN-18LM-SWW5-90CRI-MVOLT-ZT-WH	SAME AS FIXTURE TYPE 'A' EXCEPT WITH 13" DIAMETER & HIGHER LUMEN OUTPUT.	1,884	20	SURFACE CEILING
B	JUNO LIGHTING #WF6-SWW5-90CRI-MW #WF6GR-MW-JZ	6" ROUND WAFER FIXTURE WITH SWITCHABLE COLOR TEMPERATURE, WET LISTING, & WHITE FINISH. PROVIDE GOOF RING AS SPECIFIED.	1,000	13	SURFACE CEILING
C	LITHONIA LIGHTING #CPANL-2X4-AL06-SWW7-M2	2X4' FLAT PANEL LED WITH SWITCHABLE COLOR TEMPERATURE, SWTCHABLE LUMEN OUTPUT, & WHITE HOUSING.	6,000 MAX	55 MAX	RECESSED GRID
D	KUZCO LIGHTING #801003CH-LED	25" LINEAR VANITY FIXTURE WITH 3000K COLOR TEMPERATURE, CHROME FINISH, & MATTE OPAL LENS.	1,259	31	SURFACE, WALL ABOVE MIRROR
E	JUNO LIGHTING #UCES-24IN-SWW5-90CRI-WH-M6	24" LINEAR UNDER CABINET FIXTURE WITH SWITCHABLE COLOR TEMPERATURE & WHITE HOUSING.	908	17	SURFACE UNDER CABINET
E1	JUNO LIGHTING #UCES-36IN-SWW5-90CRI-WH-M6	SAME AS FIXTURE TYPE 'E' EXCEPT WITH 36" LENGTH & HIGHER LUMEN OUTPUT.	1,236	21	SURFACE UNDER CABINET
H	KUZCO LIGHTING #492316-BK/GD	'ARCHIBALD' ARCHITECTURAL PENDANT WITH 16" DIAMETER & GOLD DETAIL.	60 MAX	-	SUSPENDED
I	LITHONIA LIGHTING #CSS-L48-5000LM-MVOLT-MIN10-ZT-35K-80CRI	4' LINEAR STRIP LIGHT WITH 3500K COLOR TEMPERATURE & WHITE HOUSING.	5,078	38	SURFACE CEILING
J	MARK ARCHITECTURAL LIGHTING #SL4L-LOP-4FT-FLP-TG-80CRI-35K-400LMF-WW-ZT	4' x 4' LINEAR RECESSED FLUSH MOUNT WITH 3500K COLOR TEMPERATURE, 0-10V DIMMING, FLUSH FROSTED ACRYLIC LENS, WALL WASH DISTRIBUTION AIMED TOWARD CENTER OF CORRIDOR, & WHITE HOUSING.	1,264	16	RECESSED GRID
K	MARK ARCHITECTURAL LIGHTING #SAPID-LCB-4FT-MSL4-80CRI-35K-300LMF-180CRI-135K-1500LMF-SCT-NODIM-FLL-DC-MVOLT-WHTT-F136A-RDCY-WHTCY-WCRD	4'x4' LINEAR DIRECT/INDIRECT PENDANT FIXTURE WITH 3500K COLOR TEMPERATURE, FLUSH DIRECT LENS, DUST COVER INDIRECT LENS, AND WHITE FINISH.	3,196	22	SUSPENDED
L	LITHONIA LIGHTING #FML4W-48-AL06-SEF-835-MVOLT	10"x4' LINEAR LOW PROFILE WRAP FIXTURE WITH SWITCHABLE LUMEN OUTPUT, 3500K COLOR TEMPERATURE, & WHITE HOUSING.	6,000	49	SURFACE CEILING
N	KUZCO LIGHTING #HUDSON-WS3309	DECORATIVE WALL SCONCE WITH 9" TALL OPAL GLASS SHADE, 3000K COLOR TEMPERATURE, & BRUSHED NICKEL FINISH.	534	11	SURFACE WALL
O	KELVIX LIGHTING #UNI1-WL-1500-35K-24V #ULV96	FIELD CUTTABLE FLEXIBLE LINEAR TAPE LIGHT WITH 3500K COLOR TEMPERATURE. PROVIDE LENGTHS & CONFIGURATIONS AS INDICATED ON DRAWINGS. PROVIDE 24VDC POWER SUPPLIES AND ADDITIONAL ACCESSORIES AS REQUIRED FOR A COMPLETE INSTALLATION. INSTALL IN EXISTING ARCHITECTURAL COVES.	685FT	4FT	SURFACE COVE
P	MARK ARCHITECTURAL LIGHTING #MCLP-18IN-80CRI-35K-1500LM-180CRI-135K-11000LM-SCT-MIN10-EGLD-MVOLT-FLT-BLKT-ZT-F4120A-BLKCY-BCRD-BLKST	ROUND ARCHITECTURAL DIRECT/INDIRECT PENDANT FIXTURE WITH 18" DIAMETER, BLACK HOUSING, FLAT LENS, 3500K COLOR TEMPERATURE, 0-10V DIMMING, & ADJUSTABLE 120" SUSPENSION CABLE.	2,473	30	SUSPENDED
Q	LITHONIA LIGHTING #LDN6-35/15-L06AR-LSS-TRW-MVOLT-GZ10	6" ROUND DOWNLIGHT WITH 3500K COLOR TEMPERATURE, SEMI-SPECULAR FINISH, WHITE PAINTED FLANGE, & 0-10V DIMMING.	1,514	18	RECESSED CEILING
T	BEGA LIGHTING #B24575-K4-BLK	EXTERIOR RECESSED WALL LIGHT WITH 4000K COLOR TEMPERATURE & BLACK FINISH.	2,255	27	RECESSED WALL
U	BEGA LIGHTING #24 719-K4-BLK	SQUARE DIRECT/INDIRECT EXTERIOR SCONCE FIXTURE WITH 4000K COLOR TEMPERATURE & BLACK HOUSING.	949	20	SURFACE WALL
W	BEGA LIGHTING #B50687-K35	SEMI-RECESSED ROUND DOWNLIGHT WITH 6" DIAMETER, 3500K COLOR TEMPERATURE, & CRYSTAL GLASS LENS.	809	12	RECESSED CEILING
Y	LITHONIA LIGHTING #DSXF1-LED-P1-40K-WFL-MVOLT-YKC62-DBLXD	EXTERIOR SURFACE-MOUNTED FLOODLIGHT WITH BLACK FINISH, 4000K COLOR TEMPERATURE, & WIDE FLOOD DISTRIBUTION.	3,058	21	SURFACE
Z	WAC LIGHTING #HR-LED90-30-BL	SURFACE MOUNTED DISPLAY CASE LIGHT WITH 3" DIAMETER, 3000K COLOR TEMPERATURE, & BLACK FINISH. PROVIDE 24VDC POWER SUPPLIES AS REQUIRED FOR A COMPLETE INSTALLATION.	200	5	SURFACE DISPLAY CABINET
EM1	LITHONIA LIGHTING #ELM4L	THERMOPLASTIC EMERGENCY LIGHT WITH WHITE HOUSING & NICAD EMERGENCY BATTERY PACK.	640	4	SURFACE WALL
EM2	LITHONIA LIGHTING #AFF-CEL-DBLXD-UVOLT-LTP-SDRT-WT-CW	EXTERIOR EMERGENCY LIGHT WITH BLACK HOUSING & LITHIUM IRON PHOSPHATE EMERGENCY BATTERY PACK.	N/A	-	-
X1	LITHONIA LIGHTING #LQM-S-W-RG-MVOLT-EL-SD	THERMOPLASTIC EXIT SIGN WITH WHITE HOUSING, SWITCHABLE RED/GREEN LETTERING, NICAD EMERGENCY BATTERY PACK, & SELF-DIAGNOSTICS.	N/A	4	SURFACE WALL / CEILING
X2	HOLOPHONE #QMH-S-W-RG-MVOLT-SD	EXIT SIGN/EMERGENCY LIGHT COMBINATION UNIT WITH WHITE HOUSING, RED/GREEN SWITCHABLE LETTERING, SELF DIAGNOSTICS, & NICAD EMERGENCY BATTERY PACK.	N/A	5	SURFACE WALL / CEILING

NOTE: FIXTURES MAY BE SUBSTITUTED ON A ONE-FOR-ONE BASIS WITH APPROVAL BY PROJECT MANAGER.

LIGHTING FIXTURES

	SURFACE LIGHT FIXTURE
	RECESSED LIGHT FIXTURE
	EMERGENCY LIGHT FIXTURE
	WALL LIGHT FIXTURE - LINEAR
	STRIP LIGHT FIXTURE
	RECESSED CAN LIGHT FIXTURE
	SURFACE LIGHT FIXTURE
	PENDANT LIGHT FIXTURE
	TRACK LIGHT FIXTURE HEAD
	WALL LIGHT FIXTURE
	SELF CONTAINED EMERGENCY LIGHT
	EMERGENCY LIGHT - SINGLE HEAD
	EXIT LIGHT - WALL MOUNTED
	EXIT LIGHT - CEILING MOUNTED
	EXIT LIGHT DIRECTIONAL ARROWS
	FAN & LIGHT COMBINATION
	POLE MOUNTED AREA LIGHT FIXTURE
	FLOOD LIGHT
	WALL MOUNTED AREA LIGHT FIXTURE
	CEILING MOUNTED FAN

LIGHTING CONTROLS

	SINGLE POLE SWITCH
	DIMMER SWITCH
	OCCUPANCY SENSOR SWITCH
	THREE & FOUR WAY SWITCH
	KEY OPERATED SWITCH
	PHOTOCELL
	MOTION SENSOR (WALL & CEILING)
	OCCUPANCY SENSOR (WALL & CEILING)

CONDUITS AND CONDUCTORS

	CONDUIT OR CABLE, CONCEALED U.N.O.
	NUMBER AND SIZE OF WIRES (NO SLASHES INDICATES 3#12)
	CONDUIT HOMERUN TO PANEL (PANEL & CIRCUIT NUMBER)

LIGHT FIXTURE NOMENCLATURE

	FIXTURE TYPE PER SCHEDULE
	ASSOCIATED SWITCH OR CONTROL ZONE (NO ID = CONTROL VIA SINGLE ROOM SWITCH) (nl = NIGHT LIGHT)
	PANEL & CIRCUIT #

FIRE ALARM DEVICES

	FIRE ALARM PANEL
	HEAT DETECTOR (FIXED TEMP. AS NOTED)
	SMOKE DETECTOR
	SMOKE/CO DETECTOR COMBO
	HORN
	HORN & STROBE
	STROBE
	FIRE ALARM PULL STATION
	MAGNETIC DOOR HOLDER
	FIRE SMOKE DAMPER

GENERAL

	DASHED SYMBOL = DEVICE TO BE REMOVED
	DASHED LINE = EQUIPEMENT TO BE REMOVED

POWER DEVICES AND EQUIPMENT

	DUPLEX RECEPTACLE / QUADRAPLEX RECEPTACLE
	DUPLEX / QUADRAPLEX ABOVE COUNTER RECEPTACLE
	GFCI PROTECTED RECEPTACLE
	GFCI PROTECTED ABOVE COUNTER RECEPTACLE
	SPLIT WIRED RECEPTACLE
	SIMPLEX RECEPTACLE
	SPECIAL PURPOSE RECEPTACLE, 3Ø & 1Ø AS NOTED
	DUPLEX SMALL APPLIANCE RECEPTACLE
	DRYER RECEPTACLE, NEMA 14-30R
	ELECTRIC RANGE RECEPTACLE, NEMA 14-50R
	FLOOR MOUNTED DEVICE (RECEPTACLE SHOWN)
	CEILING MOUNTED DEVICE (RECEPTACLE SHOWN)
	POWER RECEPTACLE DROP
	JUNCTION BOX
	ELECTRIC MOTOR
	ELECTRIC MOTOR WITH STARTER SWITCH
	EXHAUST FAN
	UNIT HEATER
	CABINET UNIT HEATER
	FLUSH MOUNT ELECTRICAL PANEL - 208V & 480V
	SURFACE MOUNT ELECTRICAL PANEL - 208V & 480V
	NON-FUSED DISCONNECT SWITCH
	FUSED DISCONNECT SWITCH
	COMBINATION MOTOR/STARTER DISCONNECT SWITCH
	VFD DISCONNECT
	PUSH BUTTON OR ACCESS CONTROL JUNCTION BOX
	PUSH BUTTON OR ACCESS CONTROL BOX
	TRAFFIC CONTROL JUNCTION BOX
	WALL / FLOOR MOUNTED MODULAR FURNITURE POWER

TELECOMMUNICATION DEVICES

	TELECOMMUNICATIONS OUTLET
	TELEPHONE (VOICE) OUTLET
	FLOOR MOUNTED DEVICE (TELECOMM SHOWN)
	CEILING MOUNTED DEVICE (TELECOMM SHOWN)
	SPEAKER (WALL & CEILING)
	TELEVISION OUTLET (WALL & CEILING)
	TELEVISION/DATA COMBO OUTLET (WALL & CEILING)
	CLOCK (DIGITAL & ANALOG)
	CLOCK & SPEAKER COMBINATION
	OVERHEAD PROJECTOR

SECURITY SYSTEM DEVICES

	INTERCOM / ACCESS CONTROL MASTER STATION
	INTERCOM / ACCESS CONTROL DOOR ENTRY STATION
	ACCESS CONTROL ELECTRIC STRIKE/LOCK
	POWER SUPPLY
	DOOR CHIME
	KEYPAD
	CARD READER
	GLASS BREAK SENSOR
	SURVEILLANCE CAMERA
	VARIABLE DIRECTION SURVEILLANCE CAMERA
	DOOR BELL BUTTON

PROJECT DESCRIPTION

DESIGN INTENT IS TO REPLACE EXISTING LIGHTING FIXTURES, DEVICES, AND COVER PLATES SHOWN ON A ONE-FOR-ONE BASIS WITH NEW LED TYPE FIXTURES. CIRCUIT BREAKERS SERVING UNITS SHALL ALSO BE REPLACED WITH NEW, PROVIDE ARC FAULT AND GFCI TYPE AS INDICATED.

ALL EQUIPMENT PROVIDED SHALL COMPLY WITH THE BUY AMERICA ACT, 41 USC CHAPTER 83. CONFIRM COMPLIANCE WITH EQUIPMENT/DEVICE MANUFACTURER PRIOR TO PROCUREMENT.

ELECTRICAL ABBREVIATIONS

AC	ABOVE COUNTER
AFF	ABOVE FINISHED FLOOR
AFCI	ARC FAULT CIRCUIT INTERRUPTER
AIC	AMPERES INTERRUPTING CAPACITY
AMP, A	AMPERE
ARCH	ARCHITECTURAL
AWG	AMERICAN WIRE GAUGE
C	CONDUIT
°C	CELSIUS
CB	CIRCUIT BREAKER
CKT	CIRCUIT
CLG	CEILING
CO	CONDUIT ONLY
COMM	COMMUNICATIONS
EF	EXHAUST FAN
E.Ex.	EXISTING
EM	EMERGENCY
EMT	ELECTRICAL METALLIC TUBING
FA	FIRE ALARM
FACP	FIRE ALARM CONTROL PANEL
FLA	FULL LOAD AMPS
G, GRD	GROUND
GFCI	GROUND FAULT CURRENT INTERRUPTER
GF	GROUND FAULT PROTECTION
HP	HORSE POWER
IN, "	INCHES
K	DEGREE KELVIN
KCMIL, MCM	THOUSAND CIRCULAR MILS
KVA	KILOVOLT AMPERES
KW	KILOWATT
MAX	MAXIMUM
MCB	MAIN CIRCUIT BREAKER
MECH	MECHANICAL
MLO	MAIN LUGS ONLY
N	NEUTRAL
NC	NORMALLY CLOSED
NEC	NATIONAL ELECTRIC CODE
NIC	NOT IN CONTRACT
NO., #	NUMBER
PA	PUBLIC ADDRESS
PH, Ø	PHASE
RECP, REC	RECEPTACLE
REQ, REQD	REQUIRED
Re	RELOCATED
TELECOM	TELECOMMUNICATIONS
TV	TELEVISION
TYP	TYPICAL
UC	UNDER COUNTER
UG	UNDERGROUND
UON	UNLESS OTHERWISE NOTED
UPS	UNINTERRUPTIBLE POWER SUPPLY
UTP	UNSHIELDED TWISTED PAIR
V	VOLTS
VA	VOLT AMPERES
VFD	VARIABLE FREQUENCY DRIVE
W	WATT
WP	WEATHERPROOF

MOUNTING HEIGHT SCHEDULE

DESCRIPTION	HEIGHT
*SWITCHES	4'-0"
*RECEPTACLES	1'-6"
*WEATHERPROOF RECEPTACLES	2'-0"
BRANCH PANELS (TOP)	6'-6"
DISCONNECT SWITCHES (TOP)	5'-6"

MOUNTING HEIGHTS SHALL PREVAIL ON ALL NEW CONSTRUCTION UNLESS OTHERWISE NOTED.

MOUNTING HEIGHTS ARE TO CENTER OF DEVICE AND ABOVE FINISHED FLOOR UNLESS OTHERWISE NOTED.


COORDINATE FINAL MOUNTING HEIGHTS FOR DEVICES ABOVE COUNTERS WITH ARCHITECTURAL ELEVATIONS.

COORDINATE FINAL MOUNTING HEIGHTS FOR DEVICES FOR EQUIPMENT WITH ARCHITECTURAL ELEVATIONS.

MOUNTING FOR DEVICES SHOWN ABOVE BASEBOARD HEATERS, 4" ABOVE HEATER, MOUNTED VERTICALLY.

THESE ARE TYPICAL MOUNTING HEIGHTS. NOT ALL DEVICES ARE NECESSARILY APPLICABLE TO THIS PROJECT.

*MOUNTING HEIGHTS COMPLY WITH ICC/ANSI A117.1-09



CERTIFICATE OF AUTHORIZATION NO: T3 ALASKA, LLC AECL # 1625

spark design, llc
T3 ALASKA llc
 Mechanical & Electrical Engineering
 301 Calista Court, Suite 100
 Anchorage, AK 99516
 PH: 907-965-7900 FAX: 907-965-7975

COOK INLET HOUSING AUTHORITY
 KENAITZE RENOVATIONS
 ANCHORAGE, ALASKA

REVISION SCHEDULE		
#	DESCRIPTION	DATE

JOB NO.	2025.119.0
DATE	2026.01.16
DRAWN	SVR
REVIEWED	TCA

SHEET NAME
ABBREVIATIONS & LEGENDS,

SHEET NO.
E0.01

0'
1'

© Copyright 13 Alaska, LLC

ELECTRICAL SPECIFICATIONS

SECTION 26 05 00 - COMMON WORK RESULTS FOR ELECTRICAL

1. PROVIDE MATERIALS AND EQUIPMENT THAT ARE PRODUCTS OF MANUFACTURERS REGULARLY ENGAGED IN THE PRODUCTION OF SUCH PRODUCTS. ALL MATERIALS SHALL BE LISTED AND LABELED FOR THE APPLICATION WITH A NATIONALLY RECOGNIZED TESTING LABORATORY IN ACCORDANCE WITH NFPA 70.
2. MATERIALS AND EQUIPMENT SHALL BE INSTALLED IN ACCORDANCE WITH ALL REQUIREMENTS OF THE LATEST EDITION OF THE NATIONAL ELECTRIC CODE, STATE, MUNICIPAL, AND FEDERAL LAWS, AND AMENDMENTS GOVERNING THE PROJECT. INSTALLATION OF EQUIPMENT SHALL BE ACCORDANCE WITH THE WRITTEN INSTRUCTIONS RECOMMENDATIONS OF THE MANUFACTURER.
3. THE CONTRACTOR SHALL BECOME FAMILIAR WITH ALL DETAILS OF WORK AND VERIFY ALL DIMENSIONS IN THE FIELD SO THAT ALL OUTLETS AND EQUIPMENT ARE PROPERLY LOCATED AND READILY ACCESSIBLE.
4. LIGHTING FIXTURES, OUTLETS, AND OTHER EQUIPMENT AND MATERIALS SHALL BE COORDINATED WITH STRUCTURAL FEATURES AND ALL OTHER TRADES PRIOR TO INSTALLATION. IF ANY CONFLICTS OCCUR NECESSITATING DEPARTURES FROM THE DRAWINGS, DETAILS OF, AND REASONS FOR DEPARTURES SHALL BE SUBMITTED AND ACCEPTED PRIOR TO IMPLEMENTING ANY CHANGE.
5. THE LISTED PUBLICATIONS BELOW ESTABLISH MINIMUM REQUIREMENTS FOR MATERIALS, SYSTEMS AND EXECUTION THAT MAY BE SPECIFIED IN THIS SECTION AND UTILIZED FOR THIS PROJECT.
 - A. NATIONAL ELECTRICAL CONTRACTORS ASSOCIATION (NECA); NECA 1 - STANDARD PRACTICES FOR GOOD WORKMANSHIP IN ELECTRICAL CONSTRUCTION
 - B. NATIONAL FIRE PROTECTION ASSOCIATION (NFPA); NFPA 70 NATIONAL ELECTRICAL CODE, NFPA 70E STANDARD FOR ELECTRICAL SAFETY IN THE WORKPLACE.

SECTION 26 05 19 - POWER CONDUCTORS AND CABLES

1. PROVIDE WIRING, CABLES AND ASSOCIATED SPLICES, CONNECTORS, AND TERMINATIONS FOR WIRING SYSTEMS RATED 600 VOLTS AND LESS. CONDUCTOR AMPACITY SHALL BE BASED ON TABLE 310-16 OF THE NEC UTILIZING THE 60-DEGREE C RATING COLUMN FOR CIRCUITS TERMINATING ON DEVICES RATED BELOW 100 AMPS AND THE 75-DEGREE C RATING COLUMN FOR CIRCUITS TERMINATING ON DEVICES AND IN ENCLOSURES RATED 100 AMPS AND GREATER.
2. ALL CONDUCTORS SHALL BE COPPER UNLESS NOTED OTHERWISE. ALL CONDUCTORS INSTALLED IN UNHEATED SPACES WITHIN THE BUILDING, UNDERGROUND, OR LOCATED OUTSIDE OF THE BUILDING SHALL HAVE TYPE XHHW 90 DEGREE C INSULATION. ALL CONDUCTORS INSTALLED WITHIN HEATED SPACES MAY HAVE XHHW OR THHN 90 DEGREE C INSULATION.
3. CONDUCTORS NO. 8 AWG AND LARGER DIAMETER SHALL BE STRANDED. CONDUCTORS NO. 12 AWG AND SMALLER SHALL BE SOLID, EXCEPT THAT CONDUCTORS FOR REMOTE CONTROL, ALARM, AND SIGNAL CIRCUITS, CLASSES 1, 2, AND 3 SHALL BE STRANDED.
4. BRANCH CIRCUITS: CONDUCTORS SHALL BE NOT SMALLER THAN NO. 12 AWG. CONDUCTORS FOR BRANCH CIRCUITS OF 120 VOLTS MORE THAN 100 FEET LONG AND OF 277 VOLTS MORE THAN 200 FEET LONG FROM PANEL TO FARTHEST DEVICE OR LOAD, SHALL BE NO SMALLER THAN NO. 10 AWG. CONDUCTORS FOR BRANCH CIRCUITS OF 120 VOLTS MORE THAN 150 FEET LONG AND OF 277 VOLTS MORE THAN 300 FEET LONG FROM PANEL TO FARTHEST DEVICE OR LOAD, SHALL BE NO SMALLER THAN NO. 8 AWG.
5. TYPE NM CABLE IS ACCEPTABLE FOR USE IN THE RESIDENTIAL AREAS AS ALLOWED BY THE NATIONAL ELECTRICAL CODE.
6. INSTALL CONDUCTORS IN COMPLIANCE WITH NEC REQUIREMENTS FOR TEMPERATURE AND CONDUIT FILL DERATING AND BOX FILL LIMITATIONS.
7. COLOR CODE CONDUCTORS AS FOLLOWS:
 - A. 120/208 VOLT, 1 PHASE, 3 WIRE: BLACK, RED, WHITE
 - B. 120/208 VOLT, 3 PHASE, 4 WIRE: BLACK, RED, BLUE, WHITE
8. NEUTRAL (GROUNDED) CONDUCTOR: PROVIDE AN UNSHARED DEDICATED NEUTRAL FOR EACH CIRCUIT UNLESS SPECIFICALLY NOTED OTHERWISE. IDENTIFY GROUNDED CONDUCTORS PER NEC FOR ALL CIRCUITS
9. GROUNDING CONDUCTORS: PROVIDE A GREEN EQUIPMENT GROUNDING CONDUCTOR IN EACH NEW RACEWAY, SIZED IN ACCORDANCE WITH NFPA 70, REGARDLESS OF THE TYPE OF CONDUIT.

SECTION 26 05 33 - RACEWAYS AND BOXES FOR ELECTRICAL SYSTEMS

1. PROVIDE RACEWAYS AND BOXES LISTED AND SUITABLE FOR THE PROPOSED APPLICATION. PROVIDE AN EFFICIENTLY LAID OUT SYSTEM THAT ALLOWS FOR FUTURE GROWTH. COORDINATE RACEWAYS WITH THE WORK OF OTHER TRADES, AND COORDINATE LAYOUT AND CONSTRUCTION WITH OTHER CONSTRUCTION ELEMENTS TO ENSURE MAXIMUM HEADROOM, WORKING CLEARANCE, AND ACCESS.
2. UTILIZE RACEWAY SYSTEMS LISTED AND SUITABLE FOR THE ENVIRONMENT INSTALLED AS DEFINED BELOW:
 - A. OUTDOORS (EXPOSED): WEATHERPROOF RIGID STEEL CONDUIT OR EMT SYSTEM.
 - B. INDOORS (NOT SUBJECT TO PHYSICAL DAMAGE): EMT, MC OR NM CABLE.
 - C. CONNECTION TO VIBRATING EQUIPMENT: FLEXIBLE METAL CONDUIT, LIQUID-TIGHT IN DAMP AND WET LOCATIONS.

SECTION 26 27 26 - WIRING DEVICES

1. PROVIDE RECEPTACLES, CONNECTORS, SWITCHES, AND FINISH PLATES OF TYPES AND QUANTITIES SUITABLE FOR THE PROJECT AND INTENDED USE. WIRING DEVICES SHALL MEET NEMA WD 1 AND NEMA WD 6. WIRING TERMINALS SHALL BE OF THE SCREW TYPE OR OF THE SOLDERLESS PRESSURE TYPE HAVING SUITABLE CONDUCTOR-RELEASE ARRANGEMENT. WIRING DEVICES SHALL BE IMPACT RESISTANT NYLON WITH WHITE COLOR UNLESS NOTED OTHERWISE.
2. DEVICE PLATES ON UNFINISHED WALLS MAY BE OF ZINC-COATED SHEET STEEL, OR CAST METAL HAVING ROUNDED OR BEVELED EDGES. DEVICE AND DEVICE PLATES ON FINISHED WALLS SHALL BE WHITE AND MATCH DEVICE COLOR. SCREWS SHALL BE OF METAL WITH COUNTERSUNK HEADS, IN A COLOR TO MATCH THE FINISH OF THE PLATE.
3. SINGLE AND DUPLEX RECEPTACLES SHALL BE RATED 20 AMPERES, 125 VOLTS, 2-POLE, 3-WIRE, GROUNDING TYPE WITH POLARIZED PARALLEL SLOTS, BACK AND SIDE WIRED.
4. TOGGLE SWITCHES SHALL BE RATED 120-277 VOLT AC GROUNDING TYPE, TOTALLY ENCLOSED, GENERAL USE.

SECTION 26 51 00- INTERIOR LIGHTING

1. PROVIDE AND INSTALL ALL LIGHTING EQUIPMENT AS SHOWN ON THE DRAWINGS AND SPECIFIED IN THE LIGHTING FIXTURE SCHEDULE. PROVIDE WITH ALL OPTIONS AND ACCESSORIES AS REQUIRED FOR A COMPLETE INSTALLATION IN COMPLIANCE WITH THE MANUFACTURER'S INSTALLATION INSTRUCTIONS.
2. PAINT ALL EXPOSED RACEWAYS AND BOXES TO MATCH ADJACENT SURFACES.

SECTION 28 31 11 - DIGITAL FIRE ALARM SYSTEM

1. GENERAL: PROVIDE A COMPLETE, NON-CODED ADDRESSABLE, MICROPROCESSOR-BASED FIRE ALARM SYSTEM WITH INITIATING DEVICES, NOTIFICATION APPLIANCES, AND MONITORING AND CONTROL DEVICES AS SPECIFIED HEREIN. FURNISH AND INSTALL A COMPLETE FIRE ALARM SYSTEM AS DESCRIBED HEREIN AND AS SHOWN ON THE PLANS. INCLUDE SUFFICIENT CONTROL UNIT(S), ANNUNCIATOR(S), MANUAL STATIONS, AUTOMATIC FIRE DETECTORS, SMOKE DETECTORS, AUDIBLE AND VISIBLE NOTIFICATION APPLIANCES, WIRING, TERMINATIONS, ELECTRICAL BOXES, ETHERNET DROPS, AND ALL OTHER NECESSARY MATERIAL FOR A COMPLETE OPERATING SYSTEM. PLEASE NOTE: THE DEVICE LAYOUT AS INDICATED ON THE DRAWINGS IS DIAGRAMMATIC IN NATURE AND IS NOT INTENDED TO INDICATE A FULL INSTALLATION. RATHER IT IS INTENDED TO INDICATE SCOPE AND EXTEND OF DESIRED LAYOUTS. IT SHALL BE THE CONTRACTORS RESPONSIBILITY TO PROVIDE A FULLY CODE COMPLIANT SYSTEM.
2. UFAS - ALL UNITS MUST COMPLY WITH THE UNIFORM FEDERAL ACCESSIBILITY STANDARDS (UFAS). UNITS AND SHALL BE PROVIDED WITH FIRE ALARM DEVICES AND CONNECTIONS AS REQUIRED TO BE CODE COMPLIANT WITH SAID ACT.
3. PROVIDE SUBMITTAL AS FOLLOWS: PRODUCT DATA SHEETS FOR SYSTEM COMPONENTS HIGHLIGHTED TO INDICATE THE SPECIFIC PRODUCTS, FEATURES, OR FUNCTIONS REQUIRED TO MEET THIS SPECIFICATION. WIRING DIAGRAMS FROM MANUFACTURER, SHOP DRAWINGS SHOWING SYSTEM DETAILS INCLUDING LOCATION OF FACU, ALL DEVICES, CIRCUITING AND DETAILS OF GRAPHIC ANNUNCIATOR, SYSTEM POWER AND BATTERY CALCULATIONS AND VOLTAGE DROP CALCULATIONS TO ASSURE THAT THE SYSTEM WILL OPERATE IN ACCORDANCE WITH THE PRESCRIBED BACKUP TIME PERIODS AND UNDER ALL VOLTAGE CONDITIONS PER UL AND NFPA STANDARDS
4. SUBMISSION TO AUTHORITY HAVING JURISDICTION: IN ADDITION TO ROUTINE SUBMISSION OF THE ABOVE MATERIAL, MAKE AN IDENTICAL SUBMISSION TO THE AUTHORITY HAVING JURISDICTION. INCLUDE COPIES OF SHOP DRAWINGS AS REQUIRED TO DEPICT COMPONENT LOCATIONS TO FACILITATE REVIEW. UPON RECEIPT OF COMMENTS FROM THE AUTHORITY, MAKE RESUBMISSIONS, IF REQUIRED, TO MAKE CLARIFICATIONS OR REVISIONS TO OBTAIN APPROVAL.
5. THE FIRE ALARM SYSTEM SHALL CONSIST OF ALL NECESSARY HARDWARE EQUIPMENT AND SOFTWARE PROGRAMMING TO PERFORM THE FOLLOWING FUNCTIONS:
 6. FIRE ALARM SYSTEM DETECTION AND NOTIFICATION OPERATIONS. CONTROL AND MONITORING OF ELEVATORS, DOOR HOLD-OPEN DEVICES, FIRE SUPPRESSION SYSTEMS, AND OTHER EQUIPMENT AS INDICATED IN THE DRAWINGS AND SPECIFICATIONS. SYSTEM OPERATION DESCRIPTION INCLUDING METHOD OF OPERATION AND SUPERVISION OF EACH TYPE OF CIRCUIT AND SEQUENCE OF OPERATIONS FOR ALL MANUALLY AND AUTOMATICALLY INITIATED SYSTEM INPUTS AND OUTPUTS. A LIST OF ALL INPUT AND OUTPUT POINTS IN THE SYSTEM SHALL BE PROVIDED WITH A LABEL INDICATING LOCATION OR USE OF IDC, SLC, NAC, RELAY, SENSOR, AND AUXILIARY CONTROL CIRCUITS. OPERATING INSTRUCTIONS FOR FACU.
 7. OPERATION AND MAINTENANCE DATA FOR INCLUSION IN OPERATING AND MAINTENANCE MANUAL. INCLUDE DATA FOR EACH TYPE PRODUCT, INCLUDING ALL FEATURES AND OPERATING SEQUENCES, BOTH AUTOMATIC AND MANUAL. PROVIDE THE NAMES, ADDRESSES, AND TELEPHONE NUMBERS OF SERVICE ORGANIZATIONS.
 8. THE SYSTEM AS INDICATED IS BASED ON A EST IO SERIES. APPROVED EQUALS WILL BE CONSIDERED.
 9. INSTALL SYSTEM COMPONENTS AND ALL ASSOCIATED DEVICES IN ACCORDANCE WITH APPLICABLE NFPA STANDARDS AND MANUFACTURER'S RECOMMENDATIONS. INSTALLATION PERSONNEL SHALL BE SUPERVISED BY PERSONS WHO ARE QUALIFIED AND EXPERIENCED IN THE INSTALLATION, INSPECTION, AND TESTING OF FIRE ALARM SYSTEMS. INSTALLATION SHALL BE BY PERSONNEL LICENSED OR CERTIFIED BY STATE OF ALASKA.
 10. SEQUENCING: CONTRACTOR SHALL COORDINATE WITH THE OWNER FOR PROPER SEQUENCING FOR ALARM CONDITIONS FOR ALL ELEMENTS OF THE BUILDING AND SPECIFICALLY HOW DWELLING UNIT ALARMS ARE SEQUENCED TO COMMON AREA ALARMS.
 11. TRAINING: PROVIDE THE SERVICES OF A FACTORY-AUTHORIZED SERVICE REPRESENTATIVE TO DEMONSTRATE THE SYSTEM AND TRAIN OWNER'S MAINTENANCE PERSONNEL. PROVIDE A MINIMUM OF 4 HOURS' TRAINING. SCHEDULE TRAINING WITH THE OWNER AT LEAST SEVEN DAYS IN ADVANCE.



CERTIFICATE OF AUTHORIZATION NO:
T3 ALASKA, LLC AECL #: 1625

spark design, llc
T3 ALASKA llc
 Mechanical & Electrical Engineering
 301 Calista Court, Suite 100
 Anchorage, AK 99516
 PH: 907-665-7900 FAX: 907-665-7975

COOK INLET HOUSING AUTHORITY
KENAITZE RENOVATIONS
ANCHORAGE, ALASKA

REVISION SCHEDULE		
#	DESCRIPTION	DATE

JOB NO.	2025.119.0
DATE	2026.01.16
DRAWN	SVR
REVIEWED	TCA

SHEET NAME
SPECIFICATIONS

SHEET NO.
E0.02




CERTIFICATE OF AUTHORIZATION NO:
T3 ALASKA, LLC AECL #: 1625

spark design, llc
T3 ALASKA llc
 Mechanical & Electrical Engineering
 301 Calista Court, Suite 100
 Anchorage, AK 99516
 Ph: 907-665-7300 Fax: 907-665-7975


**COOK INLET HOUSING AUTHORITY
 KENAITZE RENOVATIONS
 ANCHORAGE, ALASKA**

GENERAL NOTES

- DESIGN INTENT IS TO REPLACE EXISTING FIXTURES AND DEVICES SHOWN ON A ONE-FOR-ONE BASIS WITH NEW LED TYPE FIXTURES AS SCHEDULED. THE CONTRACTOR SHALL BE RESPONSIBLE FOR ANY PAINTING OR PATCHING REQUIRED TO ENSURE PRODUCT LOOKS 'NEW AND ORIGINAL' AFTER INSTALLATION.
- MAINTAIN EXISTING LIGHTING CONTROL THROUGH LIGHTING CONTACTOR IN COMMON AREAS.



1 LOWER LEVEL LIGHTING PLAN - WEST WING
 SCALE: 1/8" = 1'-0"



KEY PLAN
 SCALE: NTS

REVISION SCHEDULE		
#	DESCRIPTION	DATE

JOB NO.	2025.119.0
DATE	2026.01.16
DRAWN	SVR
REVIEWED	TCA

SHEET NAME
 LOWER LEVEL
 LIGHTING PLAN
 WEST WING

SHEET NO.
E2.01



CERTIFICATE OF AUTHORIZATION NO:
T3 ALASKA, LLC AECL # 1625

spark design, llc
T3 ALASKA llc
 Mechanical & Electrical Engineering
 301 Calista Court, Suite 100
 Anchorage, AK 99516
 Ph: 907-665-7900 Fax: 907-665-7975

**COOK INLET HOUSING AUTHORITY
 KENAITZE RENOVATIONS
 ANCHORAGE, ALASKA**

REVISION SCHEDULE		
#	DESCRIPTION	DATE

JOB NO. 2025.119.0
 DATE 2026.01.16
 DRAWN SVR
 REVIEWED TCA

SHEET NAME
 FIRST FLOOR
 LIGHTING PLAN
 WEST WING

SHEET NO.
E2.02


GENERAL NOTES

- DESIGN INTENT IS TO REPLACE EXISTING FIXTURES AND DEVICES SHOWN ON A ONE-FOR-ONE BASIS WITH NEW LED TYPE FIXTURES AS SCHEDULED. THE CONTRACTOR SHALL BE RESPONSIBLE FOR ANY PAINTING OR PATCHING REQUIRED TO ENSURE PRODUCT LOOKS 'NEW AND ORIGINAL' AFTER INSTALLATION.
- MAINTAIN EXISTING LIGHTING CONTROL THROUGH LIGHTING CONTACTOR IN COMMON AREAS.

SHEET NOTES

INDICATED BY: #

- TYPE 'W' FIXTURES ARE SURFACE MOUNTED INSIDE DISPLAY CABINET.



KEY PLAN

SCALE: NTS

1 FIRST FLOOR LIGHTING PLAN - WEST WING
 SCALE: 1/8" = 1'-0"




CERTIFICATE OF AUTHORIZATION NO:
T3 ALASKA, LLC AECL # 1625

spark design, llc
T3 ALASKA llc
 Mechanical & Electrical Engineering
 301 Calista Court, Suite 100
 Anchorage, AK 99516
 Ph: 907-665-7900 Fax: 907-665-7975

**COOK INLET HOUSING AUTHORITY
 KENAITZE RENOVATIONS
 ANCHORAGE, ALASKA**

GENERAL NOTES

- DESIGN INTENT IS TO REPLACE EXISTING FIXTURES AND DEVICES SHOWN ON A ONE-FOR-ONE BASIS WITH NEW LED TYPE FIXTURES AS SCHEDULED. THE CONTRACTOR SHALL BE RESPONSIBLE FOR ANY PAINTING OR PATCHING REQUIRED TO ENSURE PRODUCT LOOKS 'NEW AND ORIGINAL' AFTER INSTALLATION.
- MAINTAIN EXISTING LIGHTING CONTROL THROUGH LIGHTING CONTACTOR IN COMMON AREAS.



KEY PLAN
SCALE: NTS

1 SECOND FLOOR LIGHTING PLAN - WEST WING
SCALE: 1/8" = 1'-0"

REVISION SCHEDULE		
#	DESCRIPTION	DATE

JOB NO.	2025.119.0
DATE	2026.01.16
DRAWN	SVR
REVIEWED	TCA

SHEET NAME
SECOND FLOOR
LIGHTING PLAN
WEST WING

SHEET NO.
E2.03



CERTIFICATE OF AUTHORIZATION NO:
T3 ALASKA, LLC AECL #: 1625

spark design, llc
T3 ALASKA llc
 Mechanical & Electrical Engineering
 301 Calista Court, Suite 100
 Anchorage, AK 99516
 PH: 907-665-7300 FAX: 907-665-7975

COOK INLET HOUSING AUTHORITY
 KENAITZE RENOVATIONS
 ANCHORAGE, ALASKA

REVISION SCHEDULE		
#	DESCRIPTION	DATE

JOB NO. 2025.119.0
 DATE 2026.01.16
 DRAWN SVR
 REVIEWED TCA

SHEET NAME
 LOWER LEVEL
 LIGHTING PLAN
 EAST WING


SHEET NO.
E2.04

GENERAL NOTES


- DESIGN INTENT IS TO REPLACE EXISTING FIXTURES AND DEVICES SHOWN ON A ONE-FOR-ONE BASIS WITH NEW LED TYPE FIXTURES AS SCHEDULED. THE CONTRACTOR SHALL BE RESPONSIBLE FOR ANY PAINTING OR PATCHING REQUIRED TO ENSURE PRODUCT LOOKS 'NEW AND ORIGINAL' AFTER INSTALLATION.
- MAINTAIN EXISTING LIGHTING CONTROL THROUGH LIGHTING CONTACTOR IN COMMON AREAS.

SHEET NOTES INDICATED BY: #

- FIXTURES IN SPACES NOTED HAVE BEEN REPLACED WITH LEDS RECENTLY AND SHALL REMAIN AS IS.



1 LOWER LEVEL LIGHTING PLAN - EAST WING
 SCALE: 1/8" = 1'-0"



KEY PLAN
 SCALE: NTS




CERTIFICATE OF AUTHORIZATION NO:
T3 ALASKA, LLC AECL #: 1625

spark design, llc
T3 ALASKA llc
 Mechanical & Electrical Engineering
 301 Calista Court, Suite 100
 Anchorage, AK 99516
 Ph: 907-665-7900 Fax: 907-665-7975


GENERAL NOTES

- DESIGN INTENT IS TO REPLACE EXISTING FIXTURES AND DEVICES SHOWN ON A ONE-FOR-ONE BASIS WITH NEW LED TYPE FIXTURES AS SCHEDULED. THE CONTRACTOR SHALL BE RESPONSIBLE FOR ANY PAINTING OR PATCHING REQUIRED TO ENSURE PRODUCT LOOKS 'NEW AND ORIGINAL' AFTER INSTALLATION.
- MAINTAIN EXISTING LIGHTING CONTROL THROUGH LIGHTING CONTACTOR IN COMMON AREAS.

**COOK INLET HOUSING AUTHORITY
 KENAITZE RENOVATIONS
 ANCHORAGE, ALASKA**



1 FIRST FLOOR LIGHTING PLAN - EAST WING
 SCALE: 1/8" = 1'-0"



KEY PLAN
 SCALE: NTS

REVISION SCHEDULE		
#	DESCRIPTION	DATE

JOB NO.	2025.119.0
DATE	2026.01.16
DRAWN	SVR
REVIEWED	TCA

SHEET NAME
 FIRST FLOOR
 LIGHTING PLAN
 EAST WING

SHEET NO.
E2.05



CERTIFICATE OF AUTHORIZATION NO:
T3 ALASKA, LLC AECL #: 1625

spark design, llc
T3 ALASKA llc
 Mechanical & Electrical Engineering
 301 Calista Court, Suite 100
 Anchorage, AK 99516
 Ph: 907-665-7900 Fax: 907-665-7975

COOK INLET HOUSING AUTHORITY
 KENAITZE RENOVATIONS
 ANCHORAGE, ALASKA

REVISION SCHEDULE		
#	DESCRIPTION	DATE


JOB NO. 2025.119.0
 DATE 2026.01.16
 DRAWN SVR
 REVIEWED TCA

SHEET NAME
 SECOND FLOOR
 LIGHTING PLAN
 EAST WING


SHEET NO.
E2.06

GENERAL NOTES

- DESIGN INTENT IS TO REPLACE EXISTING FIXTURES AND DEVICES SHOWN ON A ONE-FOR-ONE BASIS WITH NEW LED TYPE FIXTURES AS SCHEDULED. THE CONTRACTOR SHALL BE RESPONSIBLE FOR ANY PAINTING OR PATCHING REQUIRED TO ENSURE PRODUCT LOOKS 'NEW AND ORIGINAL' AFTER INSTALLATION.
- MAINTAIN EXISTING LIGHTING CONTROL THROUGH LIGHTING CONTACTOR IN COMMON AREAS.



1 SECOND FLOOR LIGHTING PLAN - EAST WING
 SCALE: 1/8" = 1'-0"



KEY PLAN
 SCALE: NTS



CERTIFICATE OF AUTHORIZATION NO:
T3 ALASKA, LLC AECL #: 1625

spark design, llc
T3 ALASKA llc
 Mechanical & Electrical Engineering
 301 Calista Court, Suite 100
 Anchorage, AK 99516
 Ph: 907-665-7900 Fax: 907-665-7975

COOK INLET HOUSING AUTHORITY
 KENAITZE RENOVATIONS
 ANCHORAGE, ALASKA

REVISION SCHEDULE		
#	DESCRIPTION	DATE


JOB NO. 2025.119.0
 DATE 2026.01.16
 DRAWN SVR
 REVIEWED TCA

SHEET NAME
 THIRD FLOOR
 LIGHTING PLAN
 EAST WING

SHEET NO.
E2.07

GENERAL NOTES

- DESIGN INTENT IS TO REPLACE EXISTING FIXTURES AND DEVICES SHOWN ON A ONE-FOR-ONE BASIS WITH NEW LED TYPE FIXTURES AS SCHEDULED. THE CONTRACTOR SHALL BE RESPONSIBLE FOR ANY PAINTING OR PATCHING REQUIRED TO ENSURE PRODUCT LOOKS 'NEW AND ORIGINAL' AFTER INSTALLATION.
- MAINTAIN EXISTING LIGHTING CONTROL THROUGH LIGHTING CONTACTOR IN COMMON AREAS.



1 THIRD FLOOR LIGHTING PLAN - EAST WING
 SCALE: 1/8" = 1'-0"



CERTIFICATE OF AUTHORIZATION NO:
T3 ALASKA, LLC AECL #: 1625

spark design, llc
T3 ALASKA llc
 Mechanical & Electrical Engineering
 301 Calista Court, Suite 100
 Anchorage, AK 99516
 Ph: 907-665-7900 Fax: 907-665-7975

COOK INLET HOUSING AUTHORITY
 KENAITZE RENOVATIONS
 ANCHORAGE, ALASKA

REVISION SCHEDULE		
#	DESCRIPTION	DATE

JOB NO.	2025.119.0
DATE	2026.01.16
DRAWN	SVR
REVIEWED	TCA

SHEET NAME
 LOWER LEVEL
 POWER & SIGNAL PLAN
 WEST WING

SHEET NO.
E3.01



GENERAL NOTES

- DESIGN INTENT IS TO REPLACE EXISTING DEVICES AND PLATES INDICATED WITH NEW DEVICES AND PLATES.

SHEET NOTES

INDICATED BY: #

- MAINTAIN EXISTING CIRCUITRY FOR REPLACEMENT OF MECHANICAL EQUIPMENT NOTED WITH NO CHANGE IN CIRCUIT LOAD.
- ELEVATOR TO BE MODERNIZED. PROVIDE NEW FUSED DISCONNECT AND CONNECTIONS AS REQUIRED BY ELEVATOR MANUFACTURER'S RECOMMENDATIONS. WHERE CODE COMPLIANT AND SUITABLE FOR INSTALLATION OF NEW DEVICES AND EQUIPMENT THE CONTRACTOR MAY REUSE EXISTING BRANCH CIRCUITRY. PROVIDE EQUIPMENT GROUNDING CONDUCTOR IN EACH REUSED CONDUIT SYSTEM WHERE ONE IS NOT CURRENTLY PROVIDED. WHERE EXISTING CIRCUITRY IS UNSUITABLE TO PROVIDE SUPPLY AND CONTROL INDICATED, PROVIDE NEW CIRCUIT AND CONTROL WIRING IN RACEWAY PER SPECIFICATIONS AND AS REQUIRED.



KEY PLAN
 SCALE: NTS

1 LOWER LEVEL POWER & SIGNAL PLAN - WEST WING
 SCALE: 1/8" = 1'-0"



CERTIFICATE OF AUTHORIZATION NO:
T3 ALASKA, LLC AECL # 1625

spark design, llc
T3 ALASKA llc
 Mechanical & Electrical Engineering
 301 Calista Court, Suite 100
 Anchorage, AK 99516
 Ph: 907-665-7300 Fax: 907-665-7975

**COOK INLET HOUSING AUTHORITY
 KENAITZE RENOVATIONS
 ANCHORAGE, ALASKA**

REVISION SCHEDULE		
#	DESCRIPTION	DATE

JOB NO.	2025.119.0
DATE	2026.01.16
DRAWN	SVR
REVIEWED	TCA

SHEET NAME
 FIRST FLOOR
 POWER & SIGNAL PLAN
 WEST WING

SHEET NO.
E3.02


GENERAL NOTES

- DESIGN INTENT IS TO REPLACE EXISTING DEVICES AND PLATES INDICATED WITH NEW DEVICES AND PLATES.

SHEET NOTES

INDICATED BY: #

- MAINTAIN EXISTING CIRCUITRY FOR REPLACEMENT OF MECHANICAL EQUIPMENT NOTED WITH NO CHANGE IN CIRCUIT LOAD.
- PROVIDE NEW RECEPTACLE AT LOCATION NOTED, COORDINATE EXACT MOUNTING HEIGHT AND LOCATION WITH FINAL EQUIPMENT SUPPLIED. CAPTURE EXISTING CIRCUIT WIRING AT ADJACENT RESTROOM RECEPTACLE AND EXTEND TO LOCATION INDICATED.



KEY PLAN

SCALE: NTS

1 FIRST FLOOR POWER & SIGNAL PLAN - WEST WING
 SCALE: 1/8" = 1'-0"



CERTIFICATE OF AUTHORIZATION NO:
T3 ALASKA, LLC AECL #: 1625

spark design, llc
T3 ALASKA llc
 Mechanical & Electrical Engineering
 301 Calista Court, Suite 100
 Anchorage, AK 99516
 PH: 907-665-7900 FAX: 907-665-7975

**COOK INLET HOUSING AUTHORITY
 KENAITZE RENOVATIONS
 ANCHORAGE, ALASKA**

REVISION SCHEDULE		
#	DESCRIPTION	DATE

JOB NO.	2025.119.0
DATE	2026.01.16
DRAWN	SVR
REVIEWED	TCA

SHEET NAME
**SECOND FLOOR
 POWER & SIGNAL PLAN
 WEST WING**

SHEET NO.
E3.03



GENERAL NOTES

- DESIGN INTENT IS TO REPLACE EXISTING DEVICES AND PLATES INDICATED WITH NEW DEVICES AND PLATES.

SHEET NOTES

INDICATED BY: **⊕**

- MAINTAIN EXISTING CIRCUITRY FOR REPLACEMENT OF MECHANICAL EQUIPMENT NOTED WITH NO CHANGE IN CIRCUIT LOAD.
- MAINTAIN EXISTING CIRCUITRY & WIRING, REPLACE SOURCE CIRCUIT BREAKER AS INDICATED ON PANEL SCHEDULES.



KEY PLAN

SCALE: NTS

1 SECOND FLOOR POWER & SIGNAL PLAN - WEST WING
 SCALE: 1/8" = 1'-0"



CERTIFICATE OF AUTHORIZATION NO:
T3 ALASKA, LLC AECL #: 1625

spark design, llc
T3 ALASKA llc
 Mechanical & Electrical Engineering
 301 Calista Court, Suite 100
 Anchorage, AK 99516
 Ph: 907-665-7900 Fax: 907-665-7975

**COOK INLET HOUSING AUTHORITY
 KENAITZE RENOVATIONS
 ANCHORAGE, ALASKA**

REVISION SCHEDULE		
#	DESCRIPTION	DATE

JOB NO. 2025.119.0
 DATE 2026.01.16
 DRAWN SVR
 REVIEWED TCA

SHEET NAME
 LOWER LEVEL
 POWER & SIGNAL PLAN
 EAST WING

SHEET NO.
E3.04


GENERAL NOTES

- DESIGN INTENT IS TO REPLACE EXISTING DEVICES AND PLATES INDICATED WITH NEW DEVICES AND PLATES.


SHEET NOTES

INDICATED BY: #

- MAINTAIN EXISTING CIRCUITRY FOR REPLACEMENT OF MECHANICAL EQUIPMENT NOTED WITH NO CHANGE IN CIRCUIT LOAD.
- PROVIDE BLANK FACE PLATES FOR (2) EXISTING FLOOR RECEPTACLES IN ROOM NOTED.



1 LOWER LEVEL POWER & SIGNAL PLAN - EAST WING
 SCALE: 1/8" = 1'-0"



KEY PLAN
 SCALE: NTS

© Copyright, T3 Alaska, LLC



CERTIFICATE OF AUTHORIZATION NO:
T3 ALASKA, LLC AECL #: 1625

spark design, llc
T3 ALASKA llc
 Mechanical & Electrical Engineering
 301 Calista Court, Suite 100
 Anchorage, AK 99516
 Ph: 907-665-7300 Fax: 907-665-7975

COOK INLET HOUSING AUTHORITY
 KENAITZE RENOVATIONS
 ANCHORAGE, ALASKA

REVISION SCHEDULE		
#	DESCRIPTION	DATE

JOB NO. 2025.119.0
 DATE 2026.01.16
 DRAWN SVR
 REVIEWED TCA

SHEET NAME
 FIRST FLOOR
 POWER & SIGNAL PLAN
 EAST WING

SHEET NO.
E3.05


GENERAL NOTES

- DESIGN INTENT IS TO REPLACE EXISTING DEVICES AND PLATES INDICATED WITH NEW DEVICES AND PLATES.


SHEET NOTES

INDICATED BY: (Ⓢ)

- MAINTAIN EXISTING CIRCUITRY FOR REPLACEMENT OF MECHANICAL EQUIPMENT NOTED WITH NO CHANGE IN CIRCUIT LOAD.



1 FIRST FLOOR POWER & SIGNAL PLAN - EAST WING
 SCALE: 1/8" = 1'-0"



KEY PLAN
 SCALE: NTS



CERTIFICATE OF AUTHORIZATION NO:
T3 ALASKA, LLC AECL #: 1625

spark design, llc
T3 ALASKA llc
 Mechanical & Electrical Engineering
 301 Calista Court, Suite 100
 Anchorage, AK 99516
 Ph: 907-665-7900 Fax: 907-665-7975

**COOK INLET HOUSING AUTHORITY
 KENAITZE RENOVATIONS
 ANCHORAGE, ALASKA**

REVISION SCHEDULE		
#	DESCRIPTION	DATE

JOB NO.	2025.119.0
DATE	2026.01.16
DRAWN	SVR
REVIEWED	TCA

SHEET NAME
**SECOND FLOOR
 POWER & SIGNAL PLAN
 EAST WING**

SHEET NO.
E3.06


GENERAL NOTES

- DESIGN INTENT IS TO REPLACE EXISTING DEVICES AND PLATES INDICATED WITH NEW DEVICES AND PLATES.


SHEET NOTES

INDICATED BY: (+)

- MAINTAIN EXISTING CIRCUITRY FOR REPLACEMENT OF MECHANICAL EQUIPMENT NOTED WITH NO CHANGE IN CIRCUIT LOAD.



1 SECOND FLOOR POWER & SIGNAL PLAN - EAST WING
 SCALE: 1/8" = 1'-0"



KEY PLAN
 SCALE: NTS



CERTIFICATE OF AUTHORIZATION NO:
T3 ALASKA, LLC AECL #: 1625

spark design, llc
T3 ALASKA llc
 Mechanical & Electrical Engineering
 301 Calista Court, Suite 100
 Anchorage, AK 99516
 Ph: 907-665-7900 Fax: 907-665-7975

**COOK INLET HOUSING AUTHORITY
 KENAITZE RENOVATIONS
 ANCHORAGE, ALASKA**

REVISION SCHEDULE		
#	DESCRIPTION	DATE

JOB NO. 2025.119.0
 DATE 2026.01.16
 DRAWN SVR
 REVIEWED TCA

SHEET NAME
 THIRD FLOOR
 POWER & SIGNAL PLAN
 EAST WING

SHEET NO.
E3.07


GENERAL NOTES

- DESIGN INTENT IS TO REPLACE EXISTING DEVICES AND PLATES INDICATED WITH NEW DEVICES AND PLATES.

SHEET NOTES

INDICATED BY:

- MAINTAIN EXISTING CIRCUITRY FOR REPLACEMENT OF MECHANICAL EQUIPMENT NOTED WITH NO CHANGE IN CIRCUIT LOAD.
- MAINTAIN EXISTING CIRCUITRY & WIRING, REPLACE SOURCE CIRCUIT BREAKER AS INDICATED ON PANEL SCHEDULES.



1 THIRD FLOOR POWER & SIGNAL PLAN - EAST WING
 SCALE: 1/8" = 1'-0"



CERTIFICATE OF AUTHORIZATION NO:
T3 ALASKA, LLC AECL# 1625

spark design, llc
T3 ALASKA llc
 Mechanical & Electrical Engineering
 301 Calista Court, Suite 100
 Anchorage, AK 99516
 Ph: 907-665-7900 Fax: 907-665-7975


COOK INLET HOUSING AUTHORITY
 KENAITZE RENOVATIONS
 ANCHORAGE, ALASKA

REVISION SCHEDULE		
#	DESCRIPTION	DATE


JOB NO. 2025.119.0
 DATE 2026.01.16
 DRAWN SVR
 REVIEWED TCA

SHEET NAME
 ENLARGED LIGHTING
 & POWER UNIT PLANS


SHEET NO.
E4.01



1 TYPICAL 2-BED UNIT LIGHTING PLAN
 SCALE: 1/4" = 1'-0"



2 TYPICAL 1-BED UNIT LIGHTING PLAN
 SCALE: 1/4" = 1'-0"




3 TYPICAL ACCESSIBLE UNIT LIGHTING PLAN
 SCALE: 1/4" = 1'-0"

GENERAL NOTES


- DESIGN INTENT IS TO REPLACE EXISTING DEVICES AND PLATES INDICATED WITH NEW DEVICES AND PLATES.
- RECEPTACLE AND SWITCH LOCATIONS IN ACCESSIBLE UNITS MAY VARY, COORDINATE EXACT LOCATIONS AND REPLACE ON A ONE-FOR-ONE BASIS. DESIGN INTENT IS NOT TO MOVE DEVICES UNLESS NOTED OTHERWISE.
- ALL CIRCUIT BREAKERS SERVING UNITS ARE TO BE REPLACED, REFERENCE PANEL SCHEDULES.

SHEET NOTES INDICATED BY: (#)


- MAINTAIN EXISTING CIRCUITRY FOR REPLACEMENT OF MECHANICAL EQUIPMENT NOTED WITH NO CHANGE IN CIRCUIT LOAD.
- STROBE INCLUDED IN ACCESSIBLE UNITS ONLY, OMIT FOR ALL OTHER UNITS.
- UNIT RESTROOMS ARE TO HAVE NIGHT LIGHTS LOCATED UNDER ROOM SWITCH REMOVED, HEAT LAMPS REMOVED, AND HEAT LAMP SWITCHES REMOVED. PROVIDE DUAL GANG FACE PLATE WITH ONE SWITCH FOR ROOM LIGHTING AND ONE BLANK.
- DISPOSAL AND SWITCH CONTROLLING DISPOSAL RECEPTACLE ARE TO BE REMOVED. PROVIDE BLANK FACE PLATE AT DISPOSAL SWITCH LOCATION. REPLACE RECEPTACLE AS INDICATED.
- CIRCUIT BREAKERS TO BE REPLACED IN EACH UNIT PANEL AS INDICATED ON TYPICAL UNIT PANEL SCHEDULE.



4 TYPICAL 2-BED UNIT POWER PLAN
 SCALE: 1/4" = 1'-0"



5 TYPICAL 1-BED UNIT POWER PLAN
 SCALE: 1/4" = 1'-0"




6 TYPICAL ACCESSIBLE UNIT POWER PLAN
 SCALE: 1/4" = 1'-0"




CERTIFICATE OF AUTHORIZATION NO:
T3 ALASKA, LLC AECL #: 1625

spark design, llc
T3 ALASKA llc
 Mechanical & Electrical Engineering
 301 Calista Court, Suite 100
 Anchorage, AK 99516
 PH: 907-665-7975

**COOK INLET HOUSING AUTHORITY
 KENAITZE RENOVATIONS
 ANCHORAGE, ALASKA**



1 ENLARGED MECHANICAL ROOM POWER DEMOLITION PLAN
 SCALE: 1/4" = 1'-0"



2 ENLARGED MECHANICAL ROOM POWER REMODEL PLAN
 SCALE: 1/4" = 1'-0"

GENERAL NOTES

- DASHED SYMBOLS INDICATE DEVICES AND EQUIPMENT TO BE REMOVED. REMOVE ASSOCIATED BRANCH CIRCUIT WIRING BACK TO SOURCE PANEL OR EXISTING UPSTREAM DEVICE TO REMAIN.
- EXISTING ELECTRICAL INFORMATION AND CIRCUITRY IS BASED ON RECORD DRAWINGS, PANEL SCHEDULES, AND A NON-DESTRUCTIVE WALK THROUGH OF THE FACILITY ONLY. THE CONTRACTOR IS RESPONSIBLE FOR VERIFYING EXISTING CONDITIONS PRIOR TO THE START OF WORK.
- DEVICES NOTED 'E' ARE EXISTING TO REMAIN AND ARE SHOWN FOR CLARITY ONLY. MAINTAIN EXISTING LOCATION AND CIRCUITRY UNLESS NOTED OTHERWISE.
- UPDATE PANEL SCHEDULES TO IDENTIFY REVISED LOADS, NEW LOADS, AND NEW SPARES AS A RESULT OF THIS PROJECT.
- WHERE CODE COMPLIANT AND SUITABLE FOR INSTALLATION OF NEW DEVICES AND EQUIPMENT, THE CONTRACTOR MAY REUSE EXISTING BRANCH CIRCUITRY. PROVIDE EQUIPMENT GROUNDING CONDUCTOR IN EACH REUSED CONDUIT SYSTEM WHERE ONE IS NOT CURRENTLY PROVIDED. WHERE EXISTING CIRCUITRY IS UNSUITABLE TO PROVIDE SUPPLY AND CONTROL INDICATED, PROVIDE NEW CIRCUIT AND CONTROL WIRING IN RACEWAY PER SPECIFICATIONS AND AS REQUIRED.

SHEET NOTES

INDICATED BY: (#)

- PROVIDE NEW COVER/DOOR FOR EXISTING PANELBOARD NOTED.
- UTILIZE EXISTING RECEPTACLE FOR NEW MECHANICAL EQUIPMENT GMT-1: 0.7A, 120V.

REVISION SCHEDULE		
#	DESCRIPTION	DATE

JOB NO.	2025.119.0
DATE	2026.01.16
DRAWN	SVR
REVIEWED	TCA

SHEET NAME
 ENLARGED MECHANICAL ROOM POWER PLANS

SHEET NO.
E4.02



CERTIFICATE OF AUTHORIZATION NO:
T3 ALASKA, LLC AECL #: 1625



COOK INLET HOUSING AUTHORITY
 KENAITZE RENOVATIONS
 ANCHORAGE, ALASKA

REVISION SCHEDULE		
#	DESCRIPTION	DATE

JOB NO.	2025.119.0
DATE	2026.01.16
DRAWN	SVR
REVIEWED	TCA

SHEET NAME
PANEL SCHEDULES

SHEET NO.
E5.01

FAULT CURRENT CALCULATION SUMMARY					ASSUMED UTILITY CONFIGURATION	
EQUIPMENT			SUPPLY FEEDER RATING AND LENGTH	FAULT CURRENT L-L	FAULT CURRENT L-N	BUS RATING
(E) UTILITY TRANS SECONDARY			N/A	14,320 A	N/A	N/A
(E) CT ENCLOSURE			6 EA. #300 AL PER PHASE	10'	14,237 A	(E) 42,000 A
(E) MDP			5 EA. #600 CU PER PHASE	40'	13,987 A	(E) 42,000 A
WEST ELEVATOR *			1 EA. #1 CU PER PHASE	115'	7,789 A	10,000 A

CONTRACTOR TO CONFIRM UTILITY ASSUMPTIONS UTILIZED FOR THIS CALCULATION AS WELL AS INSTALLED CONDUCTOR CONFIGURATIONS AND LENGTHS DURING CONSTRUCTION. REPORT ANY DECREASE IN TRANSFORMER IMPEDENCE AND INSTALLED CABLE LENGTHS AS WELL AS ANY INCREASE IN TRANSFORMER KVA RATING AND CONDUCTOR RATINGS TO ENGINEER FOR RE-EVALUATION PRIOR TO DISTRIBUTION EQUIPMENT PROCUREMENT.
* - CONFIRM ELEVATOR ELECTRICAL CONNECTION SIZE AND RATINGS WITH FINAL EQUIPMENT SUPPLIED PRIOR TO ROUGH IN.

EXISTING PANEL BC										VOLTAGE :		120/208V,3PH,4W		AMPERE RATING:		225 A	
MOUNTING:										SURFACE		MAIN CIRCUIT BREAKER RATING:		MLO		22,000 A	
SUPPLIED FROM:										PANEL SDP		SHORT CIRCUIT CURRENT RATING (SCCR):		22,000 A		22,000 A	
CKT	AMP	POLE	LOAD DESCRIPTION			PHASE A VA	PHASE B VA	PHASE C VA	LOAD DESCRIPTION			POLE	AMP	CKT			
N,GF	1	30	2	DRYER			2,500	256		LTG - CORRIDOR			1	20	2		
	3	30	2	DRYER					2,500	304	LTG - CORRIDOR			1	20	4	
N,GF	5	30	2	DRYER			2,500	1,500	2,500	539	LTG - STOR / LAUNDRY ROOMS			1	20	6	
	7	30	2	DRYER							LTG - PARKING LOT			1	20	8	
N,GF	9	20	1	WASHER					1,500	1,500	LTG - PARKING LOT			1	20	10	
N,GF	11	20	1	WASHER					1,500	800	HEAT TRACE			1	20	12	
	13	20	1	REC - LTG ELEV PIT			70				SPARE			1	20	14	
	15	20	1	REC - SUMP PUMP					865		SPARE			1	20	16	
	17	20	1	ELEV CONTROL PANEL					500	1,500	LTG, REC - EXISTING			1	20	18	
	19	20	1	REC - CORRIDOR, SMALL RMS			720				SPARE			1	20	20	
	21	20	1	REC - CORRIDOR, SMALL RMS					900		SPARE			1	20	22	
	23	20	1	REC - TV/GAME ROOM					900	200	THERMOSTATS			1	20	24	
	25	20	1	REC - FAN ROOM			540				SPARE			1	20	26	
	27	20	1	EF-2					200		SPACE			1	-	28	
	29	20	1	EF-3					1,180		SPACE			1	-	30	
	31	20	1	CUH-1, CUH-2			200				SPACE			1	-	32	
	33	20	1	SPARE							SPACE			1	-	34	
	35	20	1	FIRE SMOKE DAMPER					300		SPACE			1	-	36	
	37	-	1	SPACE							SPACE			1	-	38	
	39	-	1	SPACE							SPACE			1	-	40	
	41	-	1	SPACE							SPACE			1	-	42	
CONNECTED LOAD (VA)						8,286	7,769	9,919	25,974 VA								
CONNECTED LOAD (AMPERES)						69	65	83	72 A								
DEMAND LOAD (VA) *						8,725	8,220	10,429	27,374 VA								
DEMAND LOAD (AMPERES) *						73	69	87	76 A								

N - NEW CIRCUIT BREAKER, A - PROVIDE ARC FAULT TYPE CIRCUIT BREAKER, E - EXISTING CIRCUIT BREAKER & LOAD TO REMAIN, R - RECONFIGURED LOAD ON EXISTING CIRCUIT BREAKER
GF - PROVIDE CLASS A GFI TYPE CIRCUIT BREAKER (5mA), GP - PROVIDE CLASS B EPD TYPE CIRCUIT BREAKER (30mA), SH - PROVIDE SHUNT TRIP TYPE CIRCUIT BREAKER
* - DEMAND LOAD CALCULATED WITH LIGHTING & LARGEST MOTOR LOAD AT 125%

EXISTING PANEL BM										VOLTAGE :		120/208V,3PH,4W		AMPERE RATING:		225 A	
MOUNTING:										SURFACE		MAIN CIRCUIT BREAKER RATING:		MLO		22,000 A	
SUPPLIED FROM:										PANEL SDP		SHORT CIRCUIT CURRENT RATING (SCCR):		22,000 A		22,000 A	
CKT	AMP	POLE	LOAD DESCRIPTION			PHASE A VA	PHASE B VA	PHASE C VA	LOAD DESCRIPTION			POLE	AMP	CKT			
R	1	15		CP-3			683	1,656		VF-1			1	20	2		
	3	15		CP-3					683	200	HVAC CONTROL PANEL			1	20	4	
	5	15		CP-3							UNIT HEATER - MECH RM			1	20	6	
	7	15		CP-2			200	1,080			REC - MECH ROOM			1	20	8	
	9	15		CP-2					200	900	REC - MECH ROOM			1	20	10	
	11	15		CP-2						200	SPARE			1	20	12	
	13	20		SPARE							SPARE			1	20	14	
S	15	20		SPARE						170	LTG - MECH ROOM			1	20	16	
	17	20		SPARE							SPARE			1	20	18	
	19	15		SPARE					500		FIRE ALARM			1	20	20	
	21	15		SPARE							SPARE			1	20	22	
	23	15		SPARE							SPARE			1	20	24	
	25	35		SPARE							SPARE			1	20	26	
	27	20		SPARE							SPARE			1	20	28	
	29	20		SPARE							SPARE			1	20	30	
R	31	20	1	CP-1, CP-4, CP-5, CP-6			1,110				SPARE			1	20	32	
E	33	25	1	SPARE							SPARE			1	20	34	
R	35	20	1	DCP-1, TV-1					245		SPARE			1	20	36	
R	37	25	1	BOILER 1, BOILER PUMP 1			1,639				SPARE			1	20	38	
R	39	25	1	BOILER 2, BOILER PUMP 2				1,639			SPARE			1	20	40	
R	41	25	1	BOILER 3, BOILER PUMP 3					1,639		SPARE			1	20	42	
CONNECTED LOAD (VA)						6,868	3,792	3,631	14,292 VA								
CONNECTED LOAD (AMPERES)						57	32	30	40 A								
DEMAND LOAD (VA) *						7,039	4,006	3,802	14,847 VA								
DEMAND LOAD (AMPERES) *						59	33	32	41 A								

N - NEW CIRCUIT BREAKER, A - PROVIDE ARC FAULT TYPE CIRCUIT BREAKER, E - EXISTING CIRCUIT BREAKER & LOAD TO REMAIN, R - RECONFIGURED LOAD ON EXISTING CIRCUIT BREAKER
GF - PROVIDE CLASS A GFI TYPE CIRCUIT BREAKER (5mA), GP - PROVIDE CLASS B EPD TYPE CIRCUIT BREAKER (30mA), SH - PROVIDE SHUNT TRIP TYPE CIRCUIT BREAKER
* - DEMAND LOAD CALCULATED WITH LIGHTING & LARGEST MOTOR LOAD AT 125%

EXISTING PANEL BG										VOLTAGE :		120/208V,3PH,4W		AMPERE RATING:		225 A	
MOUNTING:										SURFACE		MAIN CIRCUIT BREAKER RATING:		MLO		22,000 A	
SUPPLIED FROM:										MDP		SHORT CIRCUIT CURRENT RATING (SCCR):		22,000 A		22,000 A	
CKT	AMP	POLE	LOAD DESCRIPTION			PHASE A VA	PHASE B VA	PHASE C VA	LOAD DESCRIPTION			POLE	AMP	CKT			
N,GF	1	30	2	DRYER			2,500	336		LTG - CORRIDOR			1	20	2		
	3	30	2	DRYER					2,500	143	LTG - CORRIDOR			1	20	4	
N,GF	5	30	2	DRYER			2,500	196	2,500	360	LTG - CORRIDOR			1	20	6	
	7	30	2	DRYER							LTG - STOR, LAUNDRY ROOMS			1	20	8	
N,GF	9	30	2	DRYER					2,500	100	LTG - REFUSE, STORAGE			1	20	10	
	11	20	1	WASHER							EF-2			1	20	12	
N,GF	13	20	1	WASHER			1,500	400			HEAT TRACE			1	20	14	
N,GF	15	20	1	WASHER					1,500	702	LTG - CRAFTS ROOM			1	20	16	
N,GF	17	20	1	WASHER					1,500	330	LTG - TRAINING ROOM			1	20	18	
	19	20	1	REC - LTG ELEV PIT			330	360			REC - CRAFTS ROOM			1	20	20	
	21	20	1	SUMP PUMP					865	360	REC - CRAFTS ROOM			1	20	22	
	23	20	1	ELEVATOR CAB					1,200	360	REC - CRAFTS ROOM			1	20	24	
N,A	25	20	1	REC - CORRIDOR / ROOMS			1,080	540			REC - ELECTRICAL ROOM			1	20	26	
N,A	27	20	1	REC - CORRIDOR / ROOMS					1,360	540	REC - TRAINING ROOM			1	20	28	
	29	20	1	REC - STORAGE					1,080	540	REC - TRAINING ROOM			1	20	30	
	31	20	1	REC - STORAGE			900	540			REC - TRAINING ROOM			1	20	32	
	33	20	1	REC - FAN ROOM					720	540	REC - LIBRARY			1	20	34	
	35	20	1	REC - STORAGE					720	540	REC - LIBRARY			1	20	36	
	37	20	1	EF-2			200	540			REC - LIBRARY			1	20	38	
	39	20	1	CUH-1,2,UH-1					400	360	REC - TT B ELEC RM			1	20	40	
	41	20	1	FIRE SMOKE DAMPER					300	500	FIRE ALARM PANEL			1	20	42	
CONNECTED LOAD (VA)						11,922	12,735	12,530	37,187 VA								
CONNECTED LOAD (AMPERES)						99	106	104	103 A								
DEMAND LOAD (VA) *						12,055	13,224	12,703	37,961 VA								
DEMAND LOAD (AMPERES) *						100	110	106	106 A								

N - NEW CIRCUIT BREAKER, A - PROVIDE ARC FAULT TYPE CIRCUIT BREAKER, E - EXISTING CIRCUIT BREAKER & LOAD TO REMAIN, R - RECONFIGURED LOAD ON EXISTING CIRCUIT BREAKER
GF - PROVIDE CLASS A GFI TYPE CIRCUIT BREAKER (5mA), GP - PROVIDE CLASS B EPD TYPE CIRCUIT BREAKER (30mA), SH - PROVIDE SHUNT TRIP TYPE CIRCUIT BREAKER
* - DEMAND LOAD CALCULATED WITH LIGHTING & LARGEST MOTOR LOAD AT 125%

EXISTING PANEL 1C										VOLTAGE :		120/208V,3PH,4W		AMPERE RATING:		225 A	
MOUNTING:										SURFACE		MAIN CIRCUIT BREAKER RATING:		MLO		10,000 A	
SUPPLIED FROM:										PANEL SDP		SHORT CIRCUIT CURRENT RATING (SCCR):		10,000 A		10,000 A	
CKT	AMP	POLE	LOAD DESCRIPTION			PHASE A VA	PHASE B VA	PHASE C VA	LOAD DESCRIPTION			POLE	AMP	CKT			
N,GF	1	30	2	DRYER			2,500	224		LTG - CORRIDOR			1	20	2		
	3	30	2	DRYER					2,500	224	LTG - CORRIDOR			1	20	4	
N,GF	5	30	2	DRYER			2,500	144	2,500	506	LTG - STOR, LAUNDRY ROOMS			1	20	6	
	7	30	2	DRYER							LTG - LOBBY			1	20	8	
N,GF	9	20	1	WASHER					1,500	448	LTG - COMMONS			1	20	10	
N,GF	11	20	1	WASHER					1,500	419	LTG - COMMONS			1	20	12	
E	13	20	1	REC - CORRIDOR			1,080	180			LTG - COMMONS			1	20	14	
E	15	20	1	REC - CORRIDOR					1,080	50	HEAT TRACE			1	20	16	
E	17	20	1	REC - LOBBY					1,080		SPARE			1	20	18	
E	19	20	1	REC - COMMONS			1,080	150			LTG - BACK DECK			1	20	20	
E	21	20	1	REC - COMMONS													



CERTIFICATE OF AUTHORIZATION NO: T3 ALASKA, LLC AECL# 1625

spark design, llc
T3 ALASKA llc
 Mechanical & Electrical Engineering
 301 Calista Court, Suite 100
 Anchorage, AK 99516
 PH: 907-665-7900 FAX: 907-665-7975

COOK INLET HOUSING AUTHORITY
KENAITZE RENOVATIONS
ANCHORAGE, ALASKA

REVISION SCHEDULE		
#	DESCRIPTION	DATE

JOB NO. 2025.119.0
 DATE 2026.01.16
 DRAWN SVR
 REVIEWED TCA

SHEET NAME
 PANEL SCHEDULES

SHEET NO.
E5.02

TYPICAL UNIT PANEL				VOLTAGE : 120/240V, 1PH, 3W		AMPERE RATING: 60 A	
				MOUNTING: SURFACE		MAIN CIRCUIT BREAKER RATING: MLO	
				SUPPLIED FROM: VARIES		SHORT CIRCUIT CURRENT RATING (SCCR): 10,000 A	
CKT	AMP	POLE	LOAD DESCRIPTION	PHASE A VA	PHASE B VA	LOAD DESCRIPTION	POLE AMP CKT
1	50	2	RANGE	3,000	900	REC.LTG/SMOKE - BEDROOM	1 20 2
3	3	2				REC - KITCHEN & ISLAND	1 20 4
5	20	1	REC - DISHWASHER	1,000	1,500	REC - KITCHEN & RANGE HOOD	1 20 6
7	20	1	REC - UNDER SINK		180	900 REC - LIVING ROOM	1 20 8
9	20	1	UNIT LIGHTING	380	180	REC - BATHROOM	1 20 10
11	-	1	SPACE			SPACE	1 - 12
13	-	1	SPACE			SPACE	1 - 14
15	-	1	SPACE			SPACE	1 - 16
17	-	1	SPACE			SPACE	1 - 18
19	-	1	SPACE			SPACE	1 - 20
CONNECTED LOAD (VA)				6,960	5,580		12,540 VA
CONNECTED LOAD (AMPERES)				58	47		60 A
DEMAND LOAD (VA) *				6,960	5,580		12,540 VA
DEMAND LOAD (AMPERES) *				58	47		60 A

E - EXISTING CIRCUIT BREAKER & LOAD TO REMAIN, R - RECONFIGURED LOAD ON EXISTING CIRCUIT BREAKER, N - NEW CIRCUIT BREAKER & LOAD, S - NEW SPARE AS A RESULT OF THIS PROJECT
 GF - PROVIDE CLASS A GFI TYPE CIRCUIT BREAKER (5mA), GP - PROVIDE CLASS B EPD TYPE CIRCUIT BREAKER (30mA), SH - PROVIDE SHUNT TRIP TYPE CIRCUIT BREAKER
 * - THERE WILL BE A REDUCTION IN UNIT LOAD AS A RESULT OF THIS PROJECT.

EXISTING PANEL 1G				VOLTAGE : 120/208V, 3PH, 4W		AMPERE RATING: 225 A	
				MOUNTING: SURFACE		MAIN CIRCUIT BREAKER RATING: MLO	
				SUPPLIED FROM: MDP		SHORT CIRCUIT CURRENT RATING (SCCR): 10,000 A	
CKT	AMP	POLE	LOAD DESCRIPTION	PHASE A VA	PHASE B VA	PHASE C VA	LOAD DESCRIPTION POLE AMP CKT
1	30	2	DRYER	2,500	336		LTG - CORRIDOR & EMERGENCY 1 20 2
3	3	2					LTG - CORRIDOR 1 20 4
5	30	2	DRYER		2,500	143	LTG - CORRIDOR & EMERGENCY 1 20 6
7	3	2		2,500		2,500	SPARE 1 20 8
9	30	2	DRYER		2,500	500	TRASH INTERLOCK DOORS 1 20 10
11	3	2				2,500	HEAT TRACE 1 20 12
13	20	1	WASHER	1,500			SPARE 1 20 14
15	20	1	WASHER		1,500		SPARE 1 20 16
17	20	1	WASHER			1,500	DOOR MAGS 1 20 18
19	20	1	REC - CORRIDOR, HEAT TRANSFORMERS	1,080			SPARE 1 20 20
21	20	1	REC - CORRIDOR, HEAT TRANSFORMERS		1,260		SPARE 1 20 22
23	20	1	UH-1			100	SPARE 1 20 24
25	20	1	FIRE SMOKE DAMPER	200			SPARE 1 20 26
27	20	1	SPARE		450		SPARE 1 20 28
29	20	1	SPARE				SPARE 1 20 30
31	20	1	SPARE				SPARE 1 20 32
33	20	1	SPACE				SPACE 1 - 34
35	-	1	SPACE				SPACE 1 - 36
37	-	1	SPACE				SPACE 1 - 38
39	-	1	SPACE				SPACE 1 - 40
41	-	1	SPACE				SPACE 1 - 42
CONNECTED LOAD (VA)				8,116	8,853	7,210	24,179 VA
CONNECTED LOAD (AMPERES)				68	74	60	67 A
DEMAND LOAD (VA) *				8,200	8,889	7,675	24,764 VA
DEMAND LOAD (AMPERES) *				68	74	64	69 A

N - NEW CIRCUIT BREAKER, A - PROVIDE ARC FAULT TYPE CIRCUIT BREAKER, E - EXISTING CIRCUIT BREAKER & LOAD TO REMAIN, R - RECONFIGURED LOAD ON EXISTING CIRCUIT BREAKER
 GF - PROVIDE CLASS A GFI TYPE CIRCUIT BREAKER (5mA), GP - PROVIDE CLASS B EPD TYPE CIRCUIT BREAKER (30mA), SH - PROVIDE SHUNT TRIP TYPE CIRCUIT BREAKER
 * - DEMAND LOAD CALCULATED WITH LIGHTING & LARGEST MOTOR LOAD AT 125%

EXISTING PANEL 2G				VOLTAGE : 120/208V, 3PH, 4W		AMPERE RATING: 225 A	
				MOUNTING: SURFACE		MAIN CIRCUIT BREAKER RATING: MLO	
				SUPPLIED FROM: MDP		SHORT CIRCUIT CURRENT RATING (SCCR): 10,000 A	
CKT	AMP	POLE	LOAD DESCRIPTION	PHASE A VA	PHASE B VA	PHASE C VA	LOAD DESCRIPTION POLE AMP CKT
1	30	2	DRYER	2,500	336		LTG - CORRIDOR 1 20 2
3	3	2					LTG - CORRIDOR 1 20 4
5	30	2	DRYER		2,500	143	SPARE 1 20 6
7	3	2		2,500		2,500	LTG - CORRIDOR 1 20 8
9	30	2	DRYER		2,500		SPARE 1 20 10
11	3	2				2,500	SPARE 1 20 12
13	20	1	WASHER	1,500			SPARE 1 20 14
15	20	1	WASHER		1,500		SPARE 1 20 16
17	20	1	WASHER			1,500	SPARE 1 20 18
19	20	1	REC - CORRIDOR	920			SPARE 1 20 20
21	20	1	REC - CORRIDOR		900		SPARE 1 20 22
23	20	1	REC - CORRIDOR			1,080	SPARE 1 20 24
25	20	1	EF-2	100			SPARE 1 20 26
27	20	1	UH-1		100		SPARE 1 20 28
29	20	1	FIRE SMOKE DAMPER			200	SPACE 1 20 30
31	20	1	SPACE				SPACE 1 20 32
33	20	1	SPACE				SPACE 1 20 34
35	20	1	SPACE				SPACE 1 20 36
37	-	1	SPACE				SPACE 1 20 38
39	-	1	SPACE				SPACE 1 20 40
41	-	1	SPACE				SPACE 1 20 42
CONNECTED LOAD (VA)				8,216	7,643	7,780	23,639 VA
CONNECTED LOAD (AMPERES)				68	64	65	66 A
DEMAND LOAD (VA) *				8,390	8,054	7,780	24,224 VA
DEMAND LOAD (AMPERES) *				70	67	65	67 A

N - NEW CIRCUIT BREAKER, A - PROVIDE ARC FAULT TYPE CIRCUIT BREAKER, E - EXISTING CIRCUIT BREAKER & LOAD TO REMAIN, R - RECONFIGURED LOAD ON EXISTING CIRCUIT BREAKER
 GF - PROVIDE CLASS A GFI TYPE CIRCUIT BREAKER (5mA), GP - PROVIDE CLASS B EPD TYPE CIRCUIT BREAKER (30mA), SH - PROVIDE SHUNT TRIP TYPE CIRCUIT BREAKER
 * - DEMAND LOAD CALCULATED WITH LIGHTING & LARGEST MOTOR LOAD AT 125%

EXISTING PANEL 2C				VOLTAGE : 120/208V, 3PH, 4W		AMPERE RATING: 225 A	
				MOUNTING: SURFACE		MAIN CIRCUIT BREAKER RATING: MLO	
				SUPPLIED FROM: PANEL SDP		SHORT CIRCUIT CURRENT RATING (SCCR): 10,000 A	
CKT	AMP	POLE	LOAD DESCRIPTION	PHASE A VA	PHASE B VA	PHASE C VA	LOAD DESCRIPTION POLE AMP CKT
1	30	2	DRYER	2,500	157		LTG - CORRIDOR 1 20 2
3	3	2			2,500	157	LTG - CORRIDOR 1 20 4
5	30	2	DRYER			2,500	310
7	3	2		2,500			100 EF-2 1 20 8
9	20	1	WASHER		1,500	3,720	
11	20	1	WASHER			1,500	3,720
13	20	1	REC - CORRIDOR	1,260	3,720		RTU-1 3 14
15	20	1	REC - CORRIDOR		1,260	6,240	
17	20	1	REC - ROOFTOP			360	6,240
19	20	1	SPARE		6,240		
21	20	1	FIRE SMOKE DAMPER		200	530	
23	20	1	SPARE			272	
25	20	1	SPARE				
27	20	1	SPARE				
29	20	1	SPARE				
31	20	1	SPARE				
33	20	1	SPARE				
35	20	1	SPARE				
37	20	1	SPACE				
39	-	1	SPACE				
41	-	1	SPACE				
CONNECTED LOAD (VA)				16,477	16,107	14,902	47,486 VA
CONNECTED LOAD (AMPERES)				137	134	124	132 A
DEMAND LOAD (VA) *				18,076	17,706	16,540	52,322 VA
DEMAND LOAD (AMPERES) *				151	148	138	145 A

N - NEW CIRCUIT BREAKER, A - PROVIDE ARC FAULT TYPE CIRCUIT BREAKER, E - EXISTING CIRCUIT BREAKER & LOAD TO REMAIN, R - RECONFIGURED LOAD ON EXISTING CIRCUIT BREAKER
 GF - PROVIDE CLASS A GFI TYPE CIRCUIT BREAKER (5mA), GP - PROVIDE CLASS B EPD TYPE CIRCUIT BREAKER (30mA), SH - PROVIDE SHUNT TRIP TYPE CIRCUIT BREAKER
 * - DEMAND LOAD CALCULATED WITH LIGHTING & LARGEST MOTOR LOAD AT 125%

EXISTING PANEL 3D				VOLTAGE : 120/208V, 3PH, 4W		AMPERE RATING: 225 A	
				MOUNTING: SURFACE		MAIN CIRCUIT BREAKER RATING: MLO	
				SUPPLIED FROM: MDP		SHORT CIRCUIT CURRENT RATING (SCCR): 10,000 A	
CKT	AMP	POLE	LOAD DESCRIPTION	PHASE A VA	PHASE B VA	PHASE C VA	LOAD DESCRIPTION POLE AMP CKT
1	30	2	DRYER	2,500	432		LTG - CORRIDOR 1 20 2
3	3	2			2,500	432	LTG - CORRIDOR 1 20 4
5	30	2	DRYER			2,500	432
7	3	2		2,500	9,480		
9	30	2	DRYER		2,500	9,480	
11	3	2				2,500	9,480
13	20	1	WASHER	1,500	530		
15	20	1	WASHER		1,500		
17	20	1	WASHER			1,500	
19	20	1	REC - CORRIDOR	1,080			
21	20	1	REC - CORRIDOR		1,080		
23	20	1	REC - CORRIDOR			720	
25	20	1	EF-2	100			
27	20	1	REC - ROOFTOP		360		
29	20	1	UH-1			100	
31	20	1	FIRE SMOKE DAMPER	200			
33	20	1	SPACE				
35	20	1	SPACE				
37	20	1	SPACE				
39	20	1	SPACE				
41	20	1	SPACE				
CONNECTED LOAD (VA)				18,322	17,852	17,232	53,406 VA
CONNECTED LOAD (AMPERES)				153	149	144	148 A
DEMAND LOAD (VA) *				20,800	20,330	19,710	60,840 VA
DEMAND LOAD (AMPERES) *				173	169	164	169 A

N - NEW CIRCUIT BREAKER, A - PROVIDE ARC FAULT TYPE CIRCUIT BREAKER, E - EXISTING CIRCUIT BREAKER & LOAD TO REMAIN, R - RECONFIGURED LOAD ON EXISTING CIRCUIT BREAKER
 GF - PROVIDE CLASS A GFI TYPE CIRCUIT BREAKER (5mA), GP - PROVIDE CLASS B EPD TYPE CIRCUIT BREAKER (30mA), SH - PROVIDE SHUNT TRIP TYPE CIRCUIT BREAKER
 * - DEMAND LOAD CALCULATED WITH LIGHTING & LARGEST MOTOR LOAD AT 125%

END OF ADDENDUM